



1 Willow Avenue  
 Oakdale, PA 15071  
 (724) 703-3020 Phone  
 (724) 703-3026 Facsimile  
[www.tigg.com](http://www.tigg.com)

## Operation and Maintenance Manual for CANSORB and Econosorb-L Liquid Phase Units

CONTENTS	PAGE
1.0 General	1
2.0 Installing the Cansorb & Econosorb-L Units	1
2.1 Unloading	1
2.2 Setup	1
3.0 Startup Procedures	1
3.1 Filling the Vessel with Carbon	2
3.2 Wetting and Deaerating	2
3.2.1 Backwashable System	2
3.2.2 Non-backwashable System	2
4.0 Operation	3
4.1 Post Startup Deaeration	3
4.2 Backwashing	3
4.3 Maintaining a Liquid Level in Carbon Bed	3
4.4 Prevention of Siphoning	3
4.5 Prevention of Over Pressuring	3
4.6 Effluent Sampling/Changeout Determination	3
4.7 Removing Spent Carbon	4
4.7.1 Carbon Units C35-C500	4
4.7.2 Econosorb-L 500, 1000, 2000 & 3000	4
4.7.1 Open Head Cansorb Drum Units	4
5.0 Maintenance	4
5.1 Regular Maintenance	4
5.2 Short-term Shutdown	4
5.3 Long-term Shutdown	5
6.0 Safety Considerations	4
7.0 Troubleshooting	5
7.1 High Pressure Drop	5
7.2 Carbon Loss	5
7.3 Premature Breakthrough of Organics	5
7.4 Effluent Concentration of an Organic Higher than Influent Concentration	6

### 1.0 GENERAL

The liquid flow through the CANSORB adsorbers is downflow. Aqueous and non-aqueous liquids can be treated using granular activated carbon. For most efficient utilization of the carbon two vessels should be used in series operation.

**If media other than carbon is to be used, contact a TIGG representative for any procedural changes.**

### 2.0 INSTALLING THE CANSORB AND ECONOSORB-L UNITS

#### 2.1 Unloading

Following are the empty and loaded weights of the CANSORB units. This information will dictate what equipment should be used to lift and place the vessel.

UNIT	Empty Wt.	Filled Wt.
C2XP		60
C5XP		112
C5OH		140
C5		140
ECONOSORB L		175
ECONOSORB LS		218
C15 Special		235
C15 TX		235
C15 OH		240
C20 OH		335
C25		435
C35	750	1410
C50	1040	2040
C75	1470	3470
C100	1790	4750
C200	2440	8440
C500	6500	14500
ELP-1000	1250	2250
ELP-2000	1600	3600
ELP-3000	2490	5490
CP500	900	1400
CP1000	1200	2200
CP2000	1600	3600
CP3000	2000	5000
CP5000	3200	8200

If a forklift is used the fork tubes on the unit should be used. If a crane is used it is advisable to use a properly sized spreader beam and lifting cables. **Do not use the lifting lugs to lift a vessel containing wet carbon.** They are not designed for that weight.

## 2.2 Setup

The CANSORB unit should be placed on a level concrete pad or other support. Connect the piping or hoses to the inlet and outlet flanges or nozzles. Install any gages or other appurtenances that were shipped with the system.

See Sections 4.3 & 4.4 relating to the effluent piping.

## 3.0 STARTUP PROCEDURES

After the CANSORB unit (s) have been set in place and the piping is installed (See Section 4.0) they are ready to be filled with the media unless they were shipped with the media in place.

### 3.1 Filling the vessel with carbon

In order to protect the liquid underdrain (collector) system, **uncontaminated water (liquid) must be added to the vessel prior to adding the carbon.**

A sufficient amount of water should be added so that the water level is at least 2 feet above the underdrain.

The water can be added via the process piping or through the top manway. When filling, the vent or manway must be open and the inlet on drum units must be open.

Fresh carbon generally will arrive in (1000-1100 pound) super sacks or (55 pound) bags. Each vessel may be filled by emptying the carbon container through the manway on top of the vessel. Drum units and vessels are usually prefilled with carbon at TIGG's production facilities.

After all of the carbon is in the vessel, fill the vessel with uncontaminated liquid. This can be done through the process piping (inlet or outlet) or through the manway. Filling from the bottom up is the preferred method. In the event uncontaminated water is not available, fill with contaminated water from the top down at a slow rate so that a depression is not made in the top of the carbon bed. If the process lines are used, the vent or manway should be open.

### 3.2 Wetting and Deaerating

For peak adsorption performance, as much air as possible should be removed before the adsorber is put onstream.

A bed of carbon consists of the following:

Void volume	-	40%
Pore volume	-	40%
Carbon skeleton	-	20%

Since 80% of the carbon bed volume is air, with 40% being in the pores of the carbon, **special prewetting steps must be taken.** If proper prewetting is not done, channeling will occur and high-pressure drop and/or premature breakthrough of the contaminant(s) will occur.

A relatively long time is required for water to enter the pores and displace the air since the pores in dry carbon are filled with air and some adsorbed oxygen.

Approximately 90% of the pores in dry carbon are filled with water after 24 hours at ambient temperature (70 degrees F.) and any liquid having the same viscosity. With more viscous liquids the time to wet will be longer. After 16 hours check the liquid level. If it is below the top of the carbon, add more liquid until it is above the carbon.

### 3.2.1 Backwashable System

**If there is inadequate prefiltration, and/or there are suspended solids present, backwashing will be required. In this case the carbon must be backwashed for 30-45 minutes prior to treating contaminated water.**

Backwashing accomplishes approximately 30-50% bed expansion. This is necessary so that the particles will be segregated (classified) and thereby subsequent backwashing operations won't change the relative position of the particles and destroy the mass transfer zone.

This backwash operation will also remove the air and carbon fines from the bed. If this procedure is not followed the carbon usage rate will be higher, there could be very early breakthrough and the pressure drop will be higher than desired.

CANSORB vessels (C35-C500 and CP-500 to CP-5000) are backwashable at rates up to 150% of their design maximum flow rate when filled with standard activated carbon fills – water temperature, media particle size and density may alter this value and flows should be checked during backwash operation to ensure media is not discharged from the vessel. CANSORB units can also be backflushed (expand top couple inches media only) at flows up to 50% of the maximum rated flow.

If the initial time for CANSORB prewetting is less than 2 days, backwash the adsorber two days after startup.

### 3.2.2 Non-backwashable System

Generally ECONOSORB vessels and CANSORB drum and ECONOSORB drum units are non-backwashable. However, ECONOSORB vessels (ELP-1000 to ELP-3000) can be backflushed (expand the top couple inches media only) at flows approximately 80% of their rated maximum flows. Note backflush effluent to ensure media is not

flushed out of vessel as checked for CANSORB vessels above. Furthermore, CANSORB drum units and ECONOSORB drum units may be backflushed (expand the top couple inches media only) at approximately 80% of their rated maximum flows, again checking for media discharge.

### **Option 1 – When time is available**

After the vessel has been filled with the water as described in Section 3.2 use the following procedures to remove air from the carbon and vessel:

1. Allow the adsorber to stand filled with the water for three or more days. The longer the vessel sits with water the better the deaeration. If the time can only be two days or less see Option 2.
2. Remove the water from the vessel. This can be done by (1) draining (make sure the adsorber is vented), (2) using air pressure to pressure the liquid out the outlet nozzle, **don't exceed the adsorber design pressure** or (3) siphoning out the outlet (inlet or vent must be open to the atmosphere).
3. When all of the water is out of the adsorber, the adsorber must be refilled with uncontaminated water. During this filling operation the adsorber must be vented. The water addition should continue until water exits the vent or the inlet nozzle. This step removes the air that is in the adsorber and it is now ready to be placed into operation.

### **Option 2 – When time is limited to less than two days**

When time is not available to prewet the carbon for 2 days, do the following:

1. Add uncontaminated water to the adsorber as described in Section 2.1.
2. After the time that can be allowed to wet the carbon, follow the steps described in items 2 & 3 in Option 1.
3. At this point, there is still air in the carbon pores. Therefore, after days 2 and 3 repeat steps described in items 2 & 3 in Option 1.

In a process system where water cannot be tolerated follow the same filling and draining procedures. However, add the liquid into the top of the adsorber.

## **4.0 OPERATION**

Operational flow rates, and thus contact time for a given volume of adsorbent, are a function of:

1. The liquid being treated
2. Temperature
3. Nature and concentration of the contaminants

4. Other system conditions
5. Removal (effluent) requirements

If conditions dictate a longer contact time than is possible in one unit, CANSORB units can be operated in parallel or series. Either one of these options will usually result in a lower adsorbent usage rate.

### **4.1 Post startup deaeration**

After several days of operation it is advantageous, in many cases, to drain and refill the adsorber in order to get rid of air that may not have been removed in the pre-startup deaeration operation.

### **4.2 Backwashing**

If there are suspended solids in the influent, these may be filtered by the carbon bed. If this occurs, they will usually collect on top of the bed and the pressure drop across the bed will increase. When the differential pressure drop across the bed is 8-10 psi greater than it was when the vessel was initially put onstream, the vessel should be backwashed. Use the flow rates described in Section 3.2.1.

For drum units the maximum pressure during backflushing should not be exceeded.

This operation should remove the solids and the differential pressure should return to normal. If it doesn't, repeat the backwash procedure at a higher rate if the vessels is designed to do so. Have someone observe the backwash water effluent to make sure carbon isn't being removed and to know when the water is clear.

If the backwashing operation doesn't result in lowering the differential pressure, the top few inches of the adsorbent may be loosened by raking and/or removed and discarded per an environmentally acceptable procedure.

### **4.3 Maintaining a liquid level in the carbon bed**

Since the pressure drop through a carbon bed is very low during operation at normal flow rates, it is possible to have the water level reach an equilibrium point low in the bed when the discharge is at a point lower than the top of the carbon bed. This is especially true for the CANSORB CP vessels and Econosorb LS units. Therefore, the discharge piping should be elevated so that there is a section above the top of the carbon bed or a backpressure control valve should be installed in the discharge line.

### **4.4 Prevention of siphoning**

When the flow to the CANSORB or ECONOSORB unit is stopped, there is the potential for siphoning to occur, unless provisions are made in the discharge piping to

prevent it. This is especially the case when the liquid is being discharged at an elevation lower than the top of the carbon bed.

The siphoning can be prevented by installing (1) an anti-siphon device or a short vertical section of pipe, in a Tee in the effluent pipe open to the atmosphere above the top of the CANSORB or ECONOSORB unit or (2) discharging into a tank at a level higher than the top of the CANSORB or ECONOSORB unit.

#### 4.5 Prevention of over pressuring

In addition to the filtering of suspended solids causing a pressure buildup across the carbon such things as bacteria growth, introduction of air into the bed via a pumping operation, and precipitation of metals, can cause the pressure across the carbon bed to increase.

If there is the possibility of any of these occurring and the design pressure of the vessel could be exceeded, a properly sized relief valve or rupture disc should be installed.

#### 4.6 Effluent sampling / Changeout determination

The frequency for sampling will depend on whether the influent concentration of the contaminants is relatively constant or variable.

Sampling should be done on a routine basis until it can be determined what the carbon usage rate is. Then the sampling frequency can usually be reduced.

If there is only one CANSORB unit onstream the time to affect a carbon changeout will depend on the effluent criteria set by the discharge permit.

If there are two CANSORB units operating in series, it is normally possible to allow the concentration of the contaminants in the effluent from the lead vessel to equal that of the influent. This is an indication that the carbon is saturated and thus the carbon usage is the minimum

When this occurs the lead vessel is removed from the system, the spent carbon is removed and the vessel is filled with fresh carbon. This vessel is then put in the secondary (lag) position.

Since the change out, refilling and wetting of the carbon will take 2-3 days, the system will be sized so that during this time, breakthrough will not occur in the lag vessel.

#### 4.7 Removing spent carbon

##### 4.7.1 CANSORB units C35 – C500

Spent carbon can be removed either by vacuuming or in slurry form.

If vacuum is selected, a vacuum truck or drum vacuum can be used. The CANSORB unit must be drained and the top manway removed. The carbon is subsequently removed via a non-metallic pipe or hose through the manway.

**Extreme care must be exercised to avoid damaging the internals and/or lining.**

If the carbon is to be removed in the slurry form, it can be pressured, using air or water, out the bottom 2-inch outlet. The slurry line should be connected to a vented receiving container prior to carbon removal. The receiving container should have a drain for removing excess water from the carbon, prior to transportation.

The required pressure to move the slurry is generally less than 10 psig. This depends on the length of the slurry line and the elevation of the final point of discharge.

*Note: After completing the slurry transfer, there is the possibility of a portion of spent carbon remaining in the bottom head. Therefore, open the manway to inspect the vessel. Depending on the quantity and location of the carbon, it may be necessary to use a hose to flush it into the bottom of the head and/or backwash to level carbon and then repressure the vessel.*

When the vessel is empty it is ready to be refilled. The procedures outlined in Sections 3.0 should be followed.

##### 4.7.2 CANSORB CP and ECONOSORB ELP units

The spent carbon is removed from these units via vacuum only since there is no slurry outlet connection.

##### 4.7.3 Open head CANSORB and ECONOSORB Drum units

In order to remove the spent carbon from the C5 and C15 drums, the bolt/ring closure is removed and the top is lifted or pivoted to one side.

Removing the top requires loosening the male adapter inside the top, immediately below the outlet bung.

For the C20 drum, a flex hose section of the outlet riser below the outlet bung is disconnected or used as a pivot.

The spent carbon is then dumped out and fresh carbon is put in.

The fresh carbon must be prewetted. After the carbon is wetted, the water can be removed by introducing air pressure through the inlet or siphoning through the outlet.  
**Do not exceed the drum operating pressure!**

## 5.0 MAINTENANCE

### 5.1 Regular maintenance

The CANSORB units are designed to require minimal maintenance. The following items should be inspected with regard to the carbon vessels, piping and gages:

1. Internal inspection of the vessel should be performed each time carbon is removed. This would include the lining and the collectors (underdrain).
2. Pressure gages should be checked periodically to insure proper operation
3. Piping and valving should be periodically inspected for signs of wear and/or leakage.

### 5.2 Short-term shutdown

The adsorption system is designed to operate continuously. A short-term shutdown is expected to last less than 72 hours. It is most likely to occur during a weekend shutdown or routine maintenance of the system. During a short-term shutdown, the adsorber may remain filled with water unless work is being performed on the adsorber itself. It may be necessary to close the inlet and outlet valves to prevent siphoning or drainage from the system.

### 5.3 Long-term shutdown

A long-term shutdown is most likely to occur during spent carbon change-out, changes in the system configuration, major maintenance, etc. During a long-term shutdown the adsorber should be completely drained to minimize the potential for biological growth and bed septicity.

## 6.0 SAFETY CONSIDERATIONS

The normal safety procedures that are practiced at the site should be followed.

Read the MSDS sheet for the carbon (media).

Understand the potential hazards of the stream being treated by the system. The media may contain higher concentrations of the contaminants being adsorbed than is in the influent stream. Also the media might be considered hazardous material and may require specific handling precautions.

In order to protect the vessel, a relief device such as a rupture disc or safety valve should be installed.

**WARNING: Wet drained activated carbon preferentially removes oxygen from air. In closed or partially closed containers, the oxygen concentration can reach dangerously low levels. Therefore, OSHA procedures related to entering confined low-oxygen spaces should be followed by workers who must enter a vessel containing wet carbon.**

## 7.0 TROUBLESHOOTING

There are a varied number of things that can cause poor performance of an activated carbon system. These are discussed below.

### 7.1 High pressure drop

Following are possible causes for having a high-pressure drop through the carbon. They are:

**1. Air in the bed. This is the most frequent cause of high-pressure drop.** This is mainly caused when the carbon is not properly prewetted. The other causes are incoming air due to a vortex in the tank feeding the pump and release of dissolved gases within the carbon bed.

**Solution:** Check for air by slowly closing a valve in the discharge line. Watch the pressure gage in the inlet line. If the pressure increases slowly there is air in the vessel. Drain/remove the liquid and refill the vessel while venting the air out the vent or inlet. If the problem recurs and the proper wetting procedure has been followed check for a vortex in the feed tank and/or determine if there is the possibility for degassing.

**2. Excessive fines in the carbon.** This is not a frequent cause for a high-pressure drop.

**Solution:** Backwash the carbon, if possible, at a rate of 8-10 gpm/ft<sup>2</sup> until the water exiting the vessel is clear. If the vessel cannot be backwashed and the pressure is too high to maintain the desired flow it may be necessary to remove the carbon, partially fill the vessel with water and slowly reinstall the carbon so that the fines can float on the top of the water. Then overflow the water to remove the fines.

### 3. Solids in the influent

Suspended solids or sediment in the influent will be filtered out by the carbon.

**Solution:** Open the manway or remove the top lid in the case of drums and inspect the top of the carbon bed. If the vessel can be backwashed this should solve the problem unless the solids have created a mud like cake on top of the bed. In this case manually remove the cake. If the layer to be removed is more than several inches, it may be necessary to replace with equivalent fresh carbon or if it is

expected that the carbon is near exhaustion then replace the entire bed of carbon.

If it is anticipated that the solids will always be in the feed, a filter should be installed in the influent line.

## 7.2 Carbon loss

In most carbon systems that treat water and wastewater, carbon losses are not usually excessive. They usually result from excessive backwash rates, broken underdrains or physical degradation of the carbon by strong oxidants such as chlorine.

**Solution:** Lower the backwash rate. It may be too high due to the viscosity being higher than the design value. A seasonal decrease in water temperature is usually the cause for losing carbon during backwash.

Check the effluent liquid for the presence of carbon. If granules are present then the underdrain is damaged or the piping of the inlet and outlet is reversed. Remove the carbon and repair the underdrain or repipe the inlet and outlet.

Chlorine reacts with the carbon skeleton. With prolonged contact the effluent will turn brown. The carbon must be replaced when this occurs.

## 7.3 Premature breakthrough of organics

This will occur for the following reasons:

1. Channeling in the carbon due to presence of air in the bed.
2. Insufficient contact time in the carbon bed.
3. A change in the influent concentrations of the contaminants.
4. Incomplete removal of spent carbon prior to refilling.

**Solution:** Check for air by slowly closing a valve in the discharge line. Watch the pressure gage in the inlet line. If the pressure increases slowly there is air in the vessel. Drain/remove the liquid and refill the vessel while venting the air out the vent or inlet.

Add more carbon, if possible. Otherwise reduce the flow rate or consider adding another vessel.

Remove carbon completely and refill vessel.

## 7.4 Effluent concentration of an organic higher than influent concentration

This is due to a phenomenon termed rollover. This occurs when components that are more strongly adsorbed displace compounds that are less strongly adsorbed.

**Solution:** If the contaminant is not one of the regulated organics continue to operate the system. If the eluting organic is part of the discharge permit and it is exceeding the permitted level then the carbon needs to be replaced. In order to better utilize carbon it may be desirable to add another vessel downstream so that the lead adsorber can become saturated prior to having to be removed.

**For reorders, replacement adsorbents or further technical information please contact TIGG Corporation, 1-800-925-0011**